

vvlCurrentStatus	ID	facilityName	comments_Second	county	Expr1	Expr2	latitude	longitude
NonOp	4917000	ARANSAS NATIONAL WILDLIFE REFUGE WATER PLANT	Facility contact was made but the system is still being assessed. The contact stated that he would call back Wednesday with an update. Please note the waste stream authorized for discharge is reverse osmosis reject water.	ARANSAS			0	0
NonOp	14218001	ARCHDIOCESE OF GALVESTON HOUSTON - CIRCLE LAKE RETREAT CENTER WWTP	4. No power 10. no power, not currently collecting 13. On generator within one day hopefully Phone number 281-356-6764 not functional possibly due to storm.	Montgomery				
INOP	13563001	BEACH ROAD MUD - BEACH ROAD MUD WWTP	Tornado hit, the clarifier was hit by debris, draining system and trucking wastewater to Bay City, WWTP. The collection system is a vacuum system, the was damage, They are working on fixing the system	Matagorda			28.38925	-95.57819

INOP	14578001	BLOOMINGTON ISD - BLOOMINGTON JUNIOR HIGH AND HIGH SCHOOL WWTP	School has been cancelled until 9/18/17. Power expected to be restored by 9/11/17 at which time an assessment of the WWTP can be accomplished.	Victoria			28.673399	-96.853199
INOP	11553001	BLUE RIDGE WEST MUD - BLUE RIDGE WEST MUD WWTP	Operator stated that the area is flooded but it seems that the plant is okay. Plant is still online. Cannot assess plant so overall status is unknown.	Fort Bend			29.600738	-95.509382
DES	12936001	BOLIVAR UTILITY SERVICES LLC - CRYSTAL PALACE WWTP	Crystal Palace completely destroyed, no access	Galveston			29.453711	-94.649663
NonOp	14724003	BRAZORIA COUNTY MUD 55 - BRAZORIA COUNTY MUD 55 WWTP	Facility seems to be okay but the area is flooded. Facility is still online. Facility cannot be assessed so the overall status is unknown.	Brazoria			29.437937	-95.405134

INOP	11713001	CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP	Finally able to access plant on 9/4/17 (by foot), bridge and road damage preventing vehicle access. Electrician expected on site 9/5/17 and insurance claims are underway. Entire service area evacuated, no inflow being received. Contact mentioned Ci	Harris			29.799762	-94.925949
INOP	1006000	CHEVRON PHILLIPS CEDAR BAYOU CHEMICAL PLANT		HARRIS			29.825277	-94.921944
INOP	13172002	CINCO MUD 1 - CINCO RANCH SOUTH WWTP	Waiting on a status update on WWTP. Alot of information was unknown.	Fort Bend			29.714005	-95.739029
INOP	14581001	CITY OF BRAZORIA - CITY OF BRAZORIA WWTP	The plant and lift stations are under water. Have ask for a strike team to help get the back in working order for the Texxas City SOC. All electial system are under water they are hoping the they dry out the system and they work. They will need to rep	Brazoria				

NonOp	10495149	CITY OF HOUSTON - FOREST COVE WWTP	Massive structural and electrical panels missing from Aqua Vista lift station Forest Cove Dr #1, Forest Cove Dr #2, Marina, Trail Tree Lane lift station are inoperable	Harris			30.03244	-95.24734
NonOp	10495146	CITY OF HOUSTON - KINGWOOD CENTRAL WWTP	The UV disinfection system was damaged. Temporary chlorination is being used. Ag Farm, Deer Ridge, Deer Springs, Stately Oaks, Woodland Ridge lift stations are partially operational. Aspen Bend, Bens Branch, Forest Garden, Riverchase Trail, Riverlawn,	Harris			30.04017	-95.18456
NonOp	10495109	CITY OF HOUSTON - TURKEY CREEK WWTP	Water Quality Division received an email for City of Houston (COH) on 9/8/17. COH indicates major damage is assumed. The WWTP is inaccessible due to high water. The Briar Forest list station is on generator. Fleetwood, Harvet Moon, Kirkwood #3, Mud 10	Harris			29.76751	-95.62071

INOP	10495030	CITY OF HOUSTON - WEST DISTRICT WWTP	Water Quality Division recieved an email from the City of Houston (COH) with the completed wastewater evaluation form on 9/8/17. COH indicates the overall status of the treatment plant and collection sytem is not fully known at this time. Based on the s	Harris			29.76327	-95.5611
INOP	10108001	CITY OF LIBERTY - CITY OF LIBERTY MAIN WWTP	The plant is currently under water. The city major and some of the minor lift stations are operatonal. It will be days before they will be able asset the plant. They are currently working on getting the minor lift stations up and running to get the sew	Liberty			30.049627	-94.801658
INOP	10312001	CITY OF WEST COLUMBIA - CITY OF WEST COLUMBIA WWTP	The plant and lift stations are under water. They hop to due a full assessment on the system by Friday.	Brazoria				

NonOp	11844001	FOREST GLEN INC - FOREST GLEN WWTF	#4. Facility currently pumping and hauling to Richey Rd MUD. #5. Access road washed out. 3 Aeration tanks and 1 digester and undercut tank shifted. Plumbing was pulled away from all tanks. 1 aeration tanks was cracked at the bottom and is not usable (mu	Walker				
INOP	14564001	FORT BEND COUNTY MUD 162 - FORT BEND COUNTY MUD 162 WWTP	The facility is flooded however the facility is still online. Facility cannot be assessed so the overall status is unknown.	Fort Bend			29.501539	-95.758712
INOP	13628001	FORT BEND COUNTY MUNICIPAL UTILITY DISTRICT 112 - NEW TERRITORY NORTH REGIONAL WWTP	Plant appears to be online but is flooded. Unable to assess therefore overall status is unknown.	Fort Bend			29.578085	-95.697248
INOP	10678001	HARDIN COUNTY WCID 1 - HARDIN COUNTY WCID 1		Hardin			30.166317	-94.315254

NonOp	10932001	HARRIS COUNTY - BEAR CREEK PIONEERS PARK WWTP	Plant is underwater. Unable to adequately assess. Did a drone fly over of the plant and it is flooded. The POC Stated: Control panels are currently underwater. Blowers motor needs to be replaced. Chlorine pumps need to be replaced. Chlorine drum is too	Harris			29.828227	-95.623186
NonOp	670000	HONEYWELL INTERNATIONAL ORANGE PLANT	Gravity flow collection system waiting for flood water to recede. Collection system restoration time unknown.	ORANGE			0	0
INOP	11290001	JACKRABBIT ROAD PUD - JACKRABBIT ROAD PUD WWTP	5 ft of water in facility David Walker 8322501142 has more information on the plant 09/05/2017 - Called David Walker - Facility is still underwater, getting portable generator to operate lift station, and start chlorinating wastewater -Collection system	Harris			29.83157	-95.656415

INOP	14205001	LAMAR CISD - FOSTER BRISCO SCHOOL COMPLEX	WWTP is flooded and cannot be assessed, however facility is online. Overall status is unknown.	Fort Bend			29.620353	-95.807765
NonOp	1727000	LNVA NORTH REGIONAL TREATMENT PLANT	Pumping flood water out of plant. Will assess damage.	JEFFERSON			30.063055	-94.061111
INOP	13839001	MAURICEVILLE MUD - MAURICEVILLE WWTP	3 lift stations are up, and One lift station is down. Many grinder pumps not working due to flooding.	Orange			30.226946	-93.819404
INOP	11329001	NEWPORT MUD - NEWPORT MUD WWTP	39 Million gallons of water is covering the system. No Power. They are flooded. They are next to an 8foot levee San Jacinto River. They are trying to get their hands on pumps. They evacuated the plant. They are still in need of pumps. they have pumps but	Harris			29.903102	-95.089603
NonOp	10875001	ORANGE COUNTY WCID 1 - OAK LANE WWTP	The facility is experiencing by pass. They have no power and the facility is not operational. There is not current disinfection	Orange			30.074726	-94.015628



NonOp	12113001	ORBIT SYSTEMS INC - BEECHWOOD WWTP	Unable to see the facility. The POC is not the facility owner anymore. The condition of the damage is unknown. August 28, 5 to 7 days of not having access. A mandatory evacuation. A drainage ditch must be crossed to access the facility. There is only 1 co	Brazoria			29.215485	-95.446748
NonOp	3530000	PORT ARTHUR PRODUCTS STATION	Pumps to system completely to flooded or burned up. Will need replacing. Currently using Vac truck to pump and haul tank farm water or oil sheen. System only received intermittant in flow currently not discharging.	JEFFERSON			29.886111	-93.994444
INOP	13804001	TEXAS DEPARTMENT OF CRIMINAL JUSTICE - TERRELL WWTP	Prison has been evacuated and WWTP and other systems shut down. Personnel currently on-site at prison, WWTP is still flooded and not accessible. Resources are being dedicated to addressing potable water issues.	Brazoria			29.297307	-95.540788

